



Certificate of
constancy of performance
0560-CPR-212190022
Issue: 00



Issued	14-09-2022	Replaces	
First issued	14-09-2022	Page	1 / 2

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	DC UPS
Trademark:	Konzept
Type designation:	DCU 2401 R2
Hardware / Software:	02 / 01
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer:	Konzept Energietechnik GmbH
Address:	Röntgenstr. 1
City:	23701 EUTIN
Country:	DE

and produced in the manufacturing plant(s):

Manufacturing plant:	Konzept Energietechnik GmbH
Address:	Röntgenstr. 1
City:	23701 EUTIN
Country:	DE

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-4:1997
EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006
EN 54-4:1997/AC:1999

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on 14-09-2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Managing director

CERTIFICATE

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

Notified Body No. 0560



Remarks and observations

The following conditions are applicable:

Essential characteristics of EN 54-4:	Clauses:	Performance
Performance of power supply	4, 5, 6	Pass
Operational reliability	4, 5, 6, 7, 8	Pass
Durability of operational reliability temperature resistance	9.5	Pass
Durability of operational reliability impact and vibration resistance	9.7, 9.8, 9.15	Pass
Durability of operational reliability electrical stability	9.9 to 9.13	Pass
Durability of operational reliability humidity resistance	9.6, 9.14	Pass

The product as described in this certificate includes the following type designations

- Product description: DC UPS
- Trademark: Konzept
- Type designation: DCU 2401 R2
- Hardware version: 02
- Software version: 01